

Name _____

Date _____

2 1/2" PRECONNECT (TWO PERSON)

COMPETENCY NUMBER:

INDIVIDUAL PERFORMANCE STANDARD:

OBJECTIVE: Firefighter(s) will properly stretch a 2 1/2" preconnect hose line to a designated location, assume correct positions (using webbing) and operate nozzle using all safety precautions while wearing full protective equipment and SCBA. Time starts when order is repeated and stops when water is flowing and personnel are in position.

TIME STANDARD: 2.5 Minutes

PROCEDURE		YES	NO
1.	Repeat order, "2-1/2 PRECONNECT".		
2.	Don SCBA (no mask worn).		
3.	Move to 2 1/2" pre-connect bed and pull shoulder load 1/3 out of bed and rotate under (facing away from hose bed) and place shoulder load on RIGHT shoulder. (Position load so nozzle is in front of shoulder.) Drop pull rope on ground.		
4.	Hold load with RIGHT hand and step out and away from apparatus, allowing hose to clear bed.		
5.	Step back toward apparatus making a 1/4 turn to the LEFT and grasp drag loops with left hand palm down.		
6.	Pull drag loops as you walk away. (BE SURE ALL HOSE CLEARS BED AND IS TAUT.)		
7.	Advance shoulder load toward designated site. Drop each drag loop as it becomes taut.		
8.	Flake off folds of the shoulder load with RIGHT hand as they become taut (THROW FOLDS HIGH AND TO THE RIGHT as you advance.)		
9.	Signal for water and lay nozzle down.		
10.	Nozzle operator attaches webbing to hose approximately 4' behind nozzle by looping the strap around the hose and forming a girth hitch.		
11.	Turn away from nozzle and face down the hose line toward engine. Place the arm nearest the hose through the strap so that the strap rests on your shoulder. Turn toward the hose so that the strap lies across your chest.		
12.	The second firefighter attaches their personal webbing strap in the same manner, approximately 5' behind the first firefighter's strap. Firefighters on the OPPOSITE side of the hose as the nozzle operator.)		
13.	Adjust nozzle, bleed off air and flow water appropriately.		
13.	Maintain complete control of charged hoseline.		

Time: _____

Pass Fail

Name _____

Date _____

CRITICAL CRITERIA NOT PERFORMED PROPERLY:

- Failure to pull hose correctly (no spaghetti).
- Failure to be on SCBA when entering IDLH..

COMMENTS:

EVALUATOR SIGNATURE: _____