

Name _____

Date _____

ADVANCE DRY HOSE UP A LADDER

COMPETENCY NUMBER:

INDIVIDUAL PERFORMANCE STANDARD:

OBJECTIVE: Firefighter will properly deploy ladder, deploy hose from preconnect or stretch bed, and stretch dry hose up a ladder to designated area, wearing full protective clothing and SCBA. Time starts when order is repeated and stops when water is flowing. All safety precautions will be used when operating above ground.

TIME STANDARD: 2.5 minutes

	PROCEDURE	YES	NO
1.	Repeat order, "ADVANCE HOSE UP THE LADDER DRY".		
2.	Remove ladder and throw to objective properly.		
3.	Secure ladder by heeling or tying off.		
4.	Properly pull preconnect or stretch bed. Pull shoulder load 1/3 out of bed and place on right shoulder facing away from hose bed. Step forward, allowing complete shoulder load to clear hose bed. Reach back with left hand and grab the drag loops with your palm down. Advance hose to heel of ladder, drop the drag loops as they come tight.		
5.	Flake excess hose near base of ladder.		
6.	Take nozzle under arm and over right shoulder. Nozzle will be on your back while climbing.		
7.	Properly sound floor before exiting ladder.		
8.	Pull adequate hose to surface to advance to target.		
9.	Secure hose with webbing to ladder or other stationary object.		
11.	Flake hose and signal for water.		
12.	Adjust nozzle, bleed off air and flow water appropriately		
13.	Maintain complete control of charged hoseline.		

Time: _____

Pass Fail

CRITICAL FAILURE:

- Failure to heel or secure ladder before climbing.
- Failure to secure hose to ladder or other stationary object.
- Failure to be able to advance hose up ladder.

COMMENTS:

EVALUATOR SIGNATURE: _____